

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
7662	3125 S LOCKBURN INDPLS IN 46241	3/3/1992

Owner-Contractor	Name	Address	Telephone
Owner	ROBERT PHILLIPS	3125 S LOCKBURN INDPLS IN	(000)241-2026
Driller	WATER WELLS INC	4320 KESSLER BLVD NO DR INDPLS IN	(317)257-2393
Operator	DAN WILHITE	License: 844	

Construction Details

Well	Use: Home	Drilling Method: Rotary	Pump Type: Submersible
	Depth: 89.0	Pump Setting Depth: 60.0	Water Quality: CLEAR
Casing	Length: 85.0	Material: PVC	Diameter: 4.0
Screen	Length: 4.0	Material: PVC	Diameter: 4.0
	Slot Size: .050		

Well Capacity Test	Type of Test: Air	Test Rate: 20.0 gpm	Bail Test Rate: Not available
	Drawdown: 20.0 ft.	Static Water Level: 30.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: ENVIRO PLUG	Depth: From 0.0 To 40.0
	Installation Method: PUMP	Number of Bags Used: 3.0

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION	Township: 15N
	Range: 3E	Section: NE of the NW of Section 5
	Topo Map: INDIANAPOLIS WEST	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: Not available	Location Accepted w/o Verification On: Not available
	Subdivision Name: Not available	Lot Number: Not available
	Ft W of EL: Not available	Ft N of SL: Not available
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: Not available	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: Not available
	UTM Easting: Not available	UTM Northing: Not available

Well Log

Top	Bottom	Formation
0.0	26.0	GRAVEL
26.0	48.0	CLAY
48.0	50.0	GRAVEL
50.0	84.0	GRAVEL
84.0	89.0	GRAVEL

Comments
None

Record of Water Well

Indiana Department of Natural Resources

Reference Number 63781	Driving Direction to Well 3800W	Date Completed 6/21/1973	
Owner-Contractor Owner Driller Operator	Name JAMES NALL HAMILTON BROS CLYDE MOWELL	Address 1107 N OLIN AVE Not available License Not available	Telephone Not available Not available
Construction Details			
Well	Use: Home Depth: 71.0	Drilling Method: Cable Tool Pump Setting Depth: Not available	Pump Type: Not available Water Quality: Not available
Casing	Length: 68.0	Material: Not available	Diameter: 4.0
Screen	Length: 5.0 Slot Size: 40	Material: Not available	Diameter: 3.0
Well Capacity Test	Type of Test: Pumping Drawdown: Not available	Test Rate: 10.0 gpm for 2.0 hrs. Bail Test Rate: Not available Static Water Level: Not available Bailer Drawdown: Not available	
Grouting Information	Material: Not available Installation Method: Not available	Depth: From (not available) To (not available) Number of Bags Used: Not available	
Well Abandonment	Sealing Material: Not available Installation Method: Not available	Depth: From (not available) To (not available) Number of Bags Used: Not available	
Administrative	County: MARION Range: 3E Topo Map: INDIANAPOLIS WEST Field Located By: Not available Courthouse Location By: Not available Location Accepted w/o Verification By: Not available Subdivision Name: Not available Ft W of EL: 2,700.0 Ft E of WL: Not available Ground Elevation: 728.0 Bedrock Elevation: Not available UTM Easting: 566372		
	Township: 16N Section: NE of the SE of the SW of Section 32 Grant: Not available Field Located On: Not available Courthouse Location On: Not available Location Accepted w/o Verification On: Not available Lot Number: Not available Ft N of SL: 900.0 Ft S of NL: Not available Depth of Bedrock: Not available Aquifer Elevation: 663.0 UTM Northing: 4403738		

Well Log

Top	Bottom	Formation
0.0	21.0	CLAY
21.0	30.0	SAND
30.0	65.0	CLAY
65.0	71.0	SAND

Comments

None

Record of Water Well Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
173736	Not available	Not available

Owner-Contractor	Name	Address	Telephone
Owner	RAY MEDSKER	1111 N OLIN AVE INDPLS IN	(000)637-0851
Driller	MATLOCK WELL DRILLING	4701 W MORRISINDPLS IN	(000)241-8284
Operator	Not available	License Not available	

Construction Details	Use: Home	Drilling Method: Rotary	Pump Type: Not available
Well	Depth: 133.0	Pump Setting Depth: Not available	Water Quality: CLEAR
Casing	Length: 133.0	Material: PVC	Diameter: 4.0
Screen	Length: Not available	Material: Not available	Diameter: Not available
	Slot Size: Not available		

Well Capacity Test	Type of Test: Not available	Test Rate: 10.0 gpm	Bail Test Rate: Not available
	Drawdown: Not available	Static Water Level: 40.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Administrative	County: MARION Range: 3E Topo Map: INDIANAPOLIS WEST Field Located By: Not available Courthouse Location By: Not available Location Accepted w/o Verification By: Not available Subdivision Name: Not available Ft W of EL: Not available Ft E of WL: Not available Ground Elevation: Not available Bedrock Elevation: Not available UTM Easting: Not available	Township: 16N Section: SW of the SE of Section 32 Grant: Not available Field Located On: Not available Courthouse Location On: Not available Location Accepted w/o Verification On: Not available Lot Number: Not available Ft N of SL: Not available Ft S of NL: Not available Depth of Bedrock: Not available Aquifer Elevation: Not available UTM Northing: Not available
-----------------------	--	---

Well Log

Top	Bottom	Formation
0.0	3.0	TOP SOIL
3.0	37.0	GRAVEL
37.0	65.0	CLAY
65.0	67.0	GRAVEL
67.0	96.0	CLAY
96.0	98.0	GRAVEL
98.0	130.0	CLAY
130.0	133.0	GRAVEL

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
180590	BETWEEN REONA & HOLT RD. OFF MICHIGAN	10/28/1979

Owner-Contractor	Name	Address	Telephone
Owner	CLARENCE GREGORY	4239 W. COSSELL	Not available
Driller	Not available	Not available	Not available
Operator	JOHN AUFDERHEIDE	License Not available	

Construction Details

Well	Use: Home	Drilling Method: Cable Tool	Pump Type: Not available
	Depth: Not available	Pump Setting Depth: 40.0	Water Quality: CLEAR
Casing	Length: 50.0	Material: Not available	Diameter: 4.0
Screen	Length: 5.0	Material: Not available	Diameter: 3.0
	Slot Size: 30		

Well Capacity Test	Type of Test: Bailing	Test Rate: 10.0 gpm for 1.0 hrs.	Bail Test Rate: Not available
	Drawdown: 12.0 ft.	Static Water Level: 23.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION	Township: 15N
	Range: 3E	Section: SE of the NW of Section 5
	Topo Map: INDIANAPOLIS WEST	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: TCS	Location Accepted w/o Verification On: Not available
	Subdivision Name: Not available	Lot Number: Not available
	Ft W of EL: Not available	Ft N of SL: Not available
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: Not available	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: Not available
	UTM Easting: Not available	UTM Northing: Not available

Well Log

Top	Bottom	Formation
0.0	10.0	CLAY
10.0	35.0	SAND & GRAVEL
35.0	45.0	CLAY
45.0	49.0	SOUPY SAND
49.0	52.0	SAND & GRAVEL

Comments
None

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
63779	Not available	Not available

Owner-Contractor	Name	Address	Telephone
Owner	HARDING	10	Not available
Driller	HAMILTON BROS., INC.	4025 ROCKVILLE ROAD, INDIANAPOLIS	Not available
Operator	JOHN	License	Not available

Construction Details

Well	Use: Home	Drilling Method: Cable Tool	Pump Type: Not available
	Depth: 58.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 55.0	Material: Not available	Diameter: 4.0
Screen	Length: 5.0	Material: Not available	Diameter: 3.0
	Slot Size: Not available		

Well Capacity Test

Type of Test: Not available	Test Rate: 10.0 gpm	Bail Test Rate: Not available
Drawdown: 1.0 ft.	Static Water Level: Not available	Bailer Drawdown: Not available

Grouting Information

Material: Not available	Depth: From (not available) To (not available)
Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment

Sealing Material: Not available	Depth: From (not available) To (not available)
Installation Method: Not available	Number of Bags Used: Not available

Administrative

County: MARION	Township: 16N
Range: 3E	Section: SW of the SW of the SE of Section 32
Topo Map: INDIANAPOLIS WEST	Grant: Not available
Field Located By: Not available	Field Located On: Not available
Courthouse Location By: Not available	Courthouse Location On: Not available
Location Accepted w/o Verification By: Not available	Location Accepted w/o Verification On: Not available
Subdivision Name: Not available	Lot Number: Not available
Ft W of EL: Not available	Ft N of SL: Not available
Ft E of WL: Not available	Ft S of NL: Not available
Ground Elevation: Not available	Depth of Bedrock: Not available
Bedrock Elevation: Not available	Aquifer Elevation: Not available
UTM Easting: Not available	UTM Northing: Not available

Well Log

Top	Bottom	Formation
0.0	10.0	FILL
10.0	58.0	GRAVEL

Comments

None

Record of Water Well

Indiana Department of Natural Resources

Reference Number 173680	Driving Direction to Well KESSLERWOOD DR.	Date Completed 8/15/1973
-----------------------------------	---	------------------------------------

Owner-Contractor	Name	Address	Telephone
Owner	JOHN C.	1740 KESSLERWOOD	Not available
Driller	C.A. MARTIN	6629 ACTON RD.	Not available
Operator	Not available	License Not available	

Construction Details			
Well	Use: Home	Drilling Method: Cable Tool	Pump Type: Not available
	Depth: 50.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: Not available	Material: Not available	Diameter: 4.0
Screen	Length: 5.0	Material: Not available	Diameter: 3.0
	Slot Size: 30		

Well Capacity Test	Type of Test: Pumping	Test Rate: 15.0 gpm for 2.0 hrs.	Bail Test Rate: Not available
	Drawdown: 2.0 ft.	Static Water Level: 10.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION Range: 3E Topo Map: INDIANAPOLIS WEST Field Located By: Not available Courthouse Location By: Not available Location Accepted w/o Verification By: Not available Subdivision Name: Not available Ft W of EL: Not available Ft E of WL: Not available Ground Elevation: Not available Bedrock Elevation: Not available UTM Easting: Not available	Township: 16N Section: SE of the SW of Section 3 Grant: Not available Field Located On: Not available Courthouse Location On: Not available Location Accepted w/o Verification On: Not available Lot Number: Not available Ft N of SL: Not available Ft S of NL: Not available Depth of Bedrock: Not available Aquifer Elevation: Not available UTM Northing: Not available
-----------------------	--	--

Well Log	
-----------------	--

Top	Bottom	Formation
0.0	15.0	YEL CLAY
15.0	25.0	BR HARDPAN
25.0	35.0	BLK GRAV

Comments
None

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
173741	1115 ALIN STREET	4/2/1990

Owner-Contractor	Name	Address	Telephone
Owner	RUSSELL DILL	7136 BUICK DR INDPLS IN	(000)244-9446
Driller	HAMILTON BROS INC	4025 ROCKVILLE RD INDPLS IN	(000)241-2577
Operator	ROBERT D SCHELLENBURG	License: #36	

Construction Details

Well	Use: Home	Drilling Method: Rotary	Pump Type: Submersible
	Depth: 87.0	Pump Setting Depth: 50.0	Water Quality: CLEAR
Casing	Length: 83.0	Material: PVC	Diameter: 4.0
Screen	Length: 4.0	Material: PVC	Diameter: 4.0
	Slot Size: .060		

Well Capacity Test

Type of Test: Bailing	Test Rate: 10.0 gpm for 1.0 hrs.	Bail Test Rate: Not available
Drawdown: 20.0 ft.	Static Water Level: 30.0 ft.	Bailer Drawdown: Not available

Grouting Information

Material: ENVIROPLUG	Depth: From 0.0 To 81.0
Installation Method: TREM	Number of Bags Used: 7.0

Well Abandonment

Sealing Material: Not available	Depth: From (not available) To (not available)
Installation Method: Not available	Number of Bags Used: Not available

Administrative

County: MARION	Township: 16N
Range: 3E	Section: SE of the SW of Section 32
Topo Map: INDIANAPOLIS WEST	Grant: Not available
Field Located By: Not available	Field Located On: Not available
Courthouse Location By: Not available	Courthouse Location On: Not available
Location Accepted w/o Verification By: Not available	Location Accepted w/o Verification On: Not available
Subdivision Name: Not available	Lot Number: Not available
Ft W of EL: Not available	Ft N of SL: Not available
Ft E of WL: Not available	Ft S of NL: Not available
Ground Elevation: Not available	Depth of Bedrock: Not available
Bedrock Elevation: Not available	Aquifer Elevation: Not available
UTM Easting: Not available	UTM Northing: Not available

Well Log

Top	Bottom	Formation
0.0	5.0	TOP SOIL & CLAY
5.0	37.0	GRAVEL
37.0	81.0	CLAY
81.0	87.0	GRAVEL

Comments

None

Record of Water Well

4012 Cossell

Indiana Department of Natural Resources

Reference Number 180246	Driving directions to well 4012 W COSSELL RD(300N)		Date completed Jan 13, 1977	
Owner-Contractor	Name	Address	Telephone	
Owner	LEON PEDIGO			
Driller	HAMILTON BROS INC.	PO BOX 24181, INDPLS IN		
Operator	ED RANDOLPH	License: null		
Company	PEDIGO & YOUNG			
Construction Details				
Well	Use: Home	Drilling method: Cable Tool	Pump type:	
	Depth: 62.0	Pump setting depth:	Water quality:	
Casing	Length: 59.0	Material:	Diameter: 4.0	
Screen	Length: 3.0	Material:	Diameter: 4.0 Slot size: .060	
Well Capacity Test	Type of test: Pumping	Test rate: 10.0 gpm for 1.0 hrs.	BailTest rate: gpm for hrs.	
	Drawdown: ft.	Static water level: ft.	Bailer Drawdown ft.	
Grouting Information	Material:	Depth: from to		
	Installation Method:	Number of bags used:		
Well Abandonment	Sealing material:	Depth: from to		
	Installation Method:	Number of bags used:		
Administrative	County: MARION	Township: 15N Range: 3E		
	Section: of Section 5	Topo map: INDIANAPOLIS WEST		
	Grant Number:			
	Field located by:	on:		
	Courthouse location by:	on:		
	Location accepted w/o verification by: BRUNS	on: Feb 14, 1977		
	Subdivision name:	Lot number:		
	Ft W of EL:	Ft N of SL:	Ft E of WL:	Ft S of NL:
	Ground elevation:	Depth to bedrock:	Bedrock elevation:	Aquifer elevation:
	UTM Easting:	UTM Northing:		
Well Log	Top	Bottom	Formation	
	0.0	1.0	TOPSOIL & CLAY	
	1.0	35.0	S&G	
	35.0	62.0	BR CLAY	
Comments				

Record of Water Well Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
180236	4019 W COSSELL RD, INDPLS IN 46222.	9/5/1975

Owner-Contractor	Name	Address	Telephone
Owner	DARELL GILLASPIE	4019 COSSELL RD, INDPLS IN	Not available
Driller	CLAYTON OTTINGER	RR#3, BOX 162, ZIONSVILLE IN	Not available
Operator	WM STOVALL	License Not available	

Construction Details	Use: Home	Drilling Method: Cable Tool	Pump Type: Not available
Well	Depth: 41.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 41.0	Material: Not available	Diameter: 4.0
Screen	Length: Not available	Material: Not available	Diameter: Not available
	Slot Size: #40 COOKS		

Well Capacity Test	Type of Test: Pumping	Test Rate: 10.0 gpm for 2.0 hrs.	Bail Test Rate: Not available
	Drawdown: 8.0 ft.	Static Water Level: 22.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Administrative	County: MARION Range: 3E Topo Map: INDIANAPOLIS WEST Field Located By: Not available Courthouse Location By: Not available Location Accepted w/o Verification By: TMB Subdivision Name: Not available Ft W of EL: Not available Ft E of WL: Not available Ground Elevation: Not available Bedrock Elevation: Not available UTM Easting: Not available	Township: 15N Section: NE of the SW of Section 5 Grant: Not available Field Located On: Not available Courthouse Location On: Not available Location Accepted w/o Verification On: 9/15/1975 Lot Number: Not available Ft N of SL: Not available Ft S of NL: Not available Depth of Bedrock: Not available Aquifer Elevation: Not available UTM Northing: Not available
-----------------------	--	--

Well Log

Top	Bottom	Formation
0.0	6.0	BR CLAY
6.0	15.0	DRY GRAV
15.0	18.0	BR CLAY & GRAV
18.0	23.0	SAND WATER
23.0	25.0	GRAY CLAY
25.0	41.0	WATER GRAV

Comments

None

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
54028	Not available	11/7/1970

Owner-Contractor	Name	Address	Telephone
Owner	ROBERT NORMAN	4024 COSSELL RD	Not available
Driller	HAMILTON BROS INC.	Not available	Not available
Operator	TERRY HAMILTON	License Not available	

Construction Details

Well	Use: Home	Drilling Method: Rotary	Pump Type: Not available
	Depth: 59.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 57.0	Material: Not available	Diameter: 4.0
Screen	Length: 2.0	Material: Not available	Diameter: 3.0
	Slot Size: #6		

Well Capacity Test

Type of Test: Pumping	Test Rate: 10.0 gpm for 2.0 hrs.	Bail Test Rate: Not available
Drawdown: Not available	Static Water Level: Not available	Bailer Drawdown: Not available

Grouting Information

Material: Not available	Depth: From (not available) To (not available)
Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment

Sealing Material: Not available	Depth: From (not available) To (not available)
Installation Method: Not available	Number of Bags Used: Not available

Administrative

County: MARION	Township: 15N
Range: 3E	Section: SE of the SW of the NW of Section 5
Topo Map: INDIANAPOLIS WEST	Grant: Not available
Field Located By: MCBN	Field Located On: 1/1/1992
Courthouse Location By: Not available	Courthouse Location On: Not available
Location Accepted w/o Verification By: Not available	Location Accepted w/o Verification On: Not available
Subdivision Name: Not available	Lot Number: Not available
Ft W of EL: Not available	Ft N of SL: Not available
Ft E of WL: Not available	Ft S of NL: Not available
Ground Elevation: 718.0	Depth of Bedrock: Not available
Bedrock Elevation: Not available	Aquifer Elevation: 658.0
UTM Easting: 565960	UTM Northing: 4402625

Well Log

Top	Bottom	Formation
0.0	30.0	CLAY
30.0	40.0	SAND
40.0	57.0	CLAY
57.0	60.0	SAND

Comments

None

Record of Water Well

Indiana Department of Natural Resources

CASE
310605
4/018 Vermont

Reference Number 180316		Driving directions to well		Date completed Jan 15, 1981	
Owner-Contractor	Name	Address	Telephone		
Owner	GUY CRAWFORD	4018 W VERMONT			
Driller	MATLOCK WELL DRILLING	401 W MORRIS ST			
Operator	JERRY OAKLEY	License: null			
Construction Details					
Well	Use: Home	Drilling method: Rotary	Pump type:		
	Depth: 75.0	Pump setting depth:	Water quality:		
Casing	Length: 75.0	Material:	Diameter: 4.0		
Screen	Length: 5.0	Material:	Diameter: 4.0 Slot size: #6		
Well Capacity Test	Type of test:	Test rate: gpm for hrs.	Bail Test rate: 5.0 gpm for 1.0 hrs.		
	Drawdown: ft.	Static water level: 20.0 ft.	Bailer Drawdown ft.		
Grouting Information	Material:	Depth: from to		Number of bags used:	
	Installation Method:				
Well Abandonment	Sealing material:	Depth: from to		Number of bags used:	
	Installation Method:				
Administrative	County: MARION	Township: 15N Range: 3E		Topo map: INDIANAPOLIS WEST	
	Section: NW of the SW of Section 5				
	Grant Number:				
	Field located by:	on:			
	Courthouse location by:	on:			
	Location accepted w/o verification by: BRUNS	on: Feb 19, 1981			
	Subdivision name:	Lot number:			
	Ft W of EL:	Ft N of SL:	Ft E of WL:	Ft S of NL:	
	Ground elevation:	Depth to bedrock:	Bedrock elevation:	Aquifer elevation:	
	UTM Easting:	UTM Northing:			
Well Log	Top	Bottom	Formation		
	0.0	3.0	TOPSOIL		
	3.0	10.0	OVERBURDEN		
	10.0	38.0	GRAV		
	38.0	75.0	OVERBURDEN		
Comments					

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed	
180241	Not available	1/30/1973	
Owner-Contractor	Name	Address	Telephone
Owner	EUGENE WILLIAMS	4020 COSSELL RD	Not available
Driller	HAMILTON BROS INC	Not available	Not available
Operator	RASH	License Not available	
Construction Details			
Well	Use: Home	Drilling Method: Cable Tool	Pump Type: Not available
	Depth: 51.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 51.0	Material: Not available	Diameter: 4.0
Screen	Length: 3.0	Material: Not available	Diameter: 4.0
	Slot Size: Not available		
Well Capacity Test	Type of Test: Not available	Test Rate: Not available	Bail Test Rate: 10.0 gpm for 5.0 hrs.
	Drawdown: Not available	Static Water Level: Not available	Bailer Drawdown: Not available
Grouting Information	Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	
Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	
Administrative	County: MARION	Township: 15N	
	Range: 3E	Section: 5	
	Topo Map: INDIANAPOLIS WEST	Grant: Not available	
	Field Located By: Not available	Field Located On: Not available	
	Courthouse Location By: Not available	Courthouse Location On: Not available	
	Location Accepted w/o Verification By: Not available	Location Accepted w/o Verification On: Not available	
	Subdivision Name: Not available	Lot Number: Not available	
	Ft W of EL: Not available	Ft N of SL: Not available	
	Ft E of WL: Not available	Ft S of NL: Not available	
	Ground Elevation: Not available	Depth of Bedrock: Not available	
	Bedrock Elevation: Not available	Aquifer Elevation: Not available	
	UTM Easting: Not available	UTM Northing: Not available	

Well Log

Top	Bottom	Formation
0.0	5.0	TOPSOIL & CLAY
5.0	35.0	SAND
35.0	51.0	CLAY

Comments

None

Record of Water Well

4042 Vermont

Case # 310 604

Indiana Department of Natural Resources

Reference Number 180630	Driving directions to well SPEEDWAY		Date completed Sep 22, 1961	
Owner-Contractor	Name	Address	Telephone	
Owner	CHAS GREEN	4042 W VERMONT		
Driller	MANFORD DILAN	841 W SUMNER AVE		
Operator	NOLES CREED	License: null		
Construction Details				
Well	Use: Home	Drilling method: Cable Tool	Pump type:	
	Depth: 35.0	Pump setting depth:	Water quality:	
Casing	Length: 35.0	Material:	Diameter: 4.5	
Screen	Length: 0.5	Material:	Diameter: 3.0 Slot size: 6	
Well Capacity Test	Type of test: Pumping	Test rate: 10.0 gpm for 1.5 hrs.	Bail Test rate: gpm for hrs.	
	Drawdown: 0.0 ft.	Static water level: 20.0 ft.	Bailer Drawdown: ft.	
Grouting Information	Material:	Depth: from to		
	Installation Method:	Number of bags used:		
Well Abandonment	Sealing material:	Depth: from to		
	Installation Method:	Number of bags used:		
Administrative	County: MARION		Township: 15N Range: 3E	
	Section: SE of the SW of the NW of Section 5		Topo map: INDIANAPOLIS WEST	
	Grant Number:			
	Field located by:		on:	
	Courthouse location by:		on:	
	Location accepted w/o verification by:		on:	
	Subdivision name:		Lot number:	
	Ft W of EL:	Ft N of SL:	Ft E of WL:	Ft S of NL:
	Ground elevation:	Depth to bedrock:	Bedrock elevation:	Aquifer elevation:
	UTM Easting:	UTM Northing:		
Well Log	Top	Bottom	Formation	
	0.0	5.0	YEL CLAY	
	5.0	18.0	SANDY HARDPAN	
	18.0	25.0	DRY SAND	
	25.0	35.0	S&G	
Comments				